

U.S. Government

Federal law prohibits removal of this label before consumer purchase.


# ENERGYGUIDE

Central Air Conditioner  
Cooling Only  
Split System

FRASER-JOHNSTON BY JOHNSON CONTROLS  
Model TC3B6021

## Efficiency Rating (SEER)\*

# 13.00 - 14.25



**Range of Similar Models**  
\*Seasonal Energy Efficiency Ratio


▼▼ This system's efficiency rating depends on the coil your contractor installs with this unit. Ask for details.

For energy cost info, visit [productinfo.energy.gov](http://productinfo.energy.gov)

## Notice

The installed system must meet minimum federal regional efficiency standards.

See [productinfo.energy.gov](http://productinfo.energy.gov) for certified coil combinations.



## Minimum Standards

	North	Southeast	Southwest
<b>SEER</b>	13	14	14
<b>EER†</b>			12.2
<b>EER††</b>			11.7

† Units with rated capacity of less than 45,000 btu/h

†† Units with rated capacity equal to or greater than 45,000 btu/h

**Energy Efficiency Ratio (EER):** could range from 10.75 to 12.00, depending on the coil installed with this unit